



REINFORCED CONCRETE ARCH CULVERT, STORM DRAIN AND SEWER PIPE FIELD SECTION 1035

1035.1 Scope. To establish procedures for the inspection, acceptance, and reporting of reinforced concrete arch culvert, storm drain and sewer pipe.

1035.2 Apparatus.

- (a) Rule with suitable graduations to accurately measure the material to be inspected.
- (b) OK - MoDOT stamp.
- (c) Weather resistant marking material.

1035.3 Procedure. All requirements for this pipe are specified in AASHTO M206 except the material requirements for cement, coarse aggregate, and fine aggregate are specified in Specification Sec 1035. The basis of acceptance are specified in AASHTO M206 and the procedures for inspecting and reporting shall be as described in [Field Sec 1026](#) of this Manual.

1035.3.1 Procedures for submitting special or modified designs are described in [Field Sec 1026](#) of this Manual.

1035.4 Report. All reports of materials and inspections are to be made in accordance with [Field Sec 1026](#) of this Manual.

